

Existing Area Source Boiler with Biomass Fuel Subcategory

| Capacity or Use Type | Oxygen Trim System? | Initial Notice of Applicability | Conduct an Initial Tune-up | Tune-up Frequency | Submit Notification of Compliance Status for Tune-ups | Complete One-Time Energy Assessment | Submit Notification of Compliance Status for Energy Assessment | Required to Meet Emission Limits | Submit Notification of Compliance Status for Emission Limits | Emission Performance Test Frequency |
|-------------------------------------|---------------------|---------------------------------|----------------------------|----------------------|--|-------------------------------------|--|----------------------------------|--|-------------------------------------|
| Any Capacity | Yes | 01/20/14 | 03/21/14 | Every five (5) years | Every March 1 st after a tune-up is completed | – | – | – | – | – |
| | No | 01/20/14 | 03/21/14 | Every two (2) years | Every March 1 st after a tune-up is completed | – | – | – | – | – |
| ≥ 10 MMBTU/hr | Yes | 01/20/14 | 03/21/14 | Every five (5) years | Every March 1 st after a tune-up is completed | 03/21/14 | 07/19/14 | – | – | – |
| ≥ 10 MMBTU/hr | No | 01/20/14 | 03/21/14 | Every two (2) years | Every March 1 st after a tune-up is completed | 03/21/14 | 07/19/14 | – | – | – |
| < 10 MMBTU/hr <i>Seasonal</i> | - | 01/20/14 | 03/21/14 | Every five (5) years | Every March 1 st after a tune-up is completed | – | – | – | – | – |
| ≥ 10 MMBTU/hr <i>Seasonal</i> | - | 01/20/14 | 03/21/14 | Every five (5) years | Every March 1 st after a tune-up is completed | 03/21/14 | 07/19/14 | – | – | – |
| < 10 MMBTU/hr <i>Limited Use</i> | - | 01/20/14 | 03/21/14 | Every five (5) years | Every March 1 st after a tune-up is completed | – | – | – | – | – |
| ≥ 10 MMBTU/hr <i>Limited Use</i> | - | 01/20/14 | 03/21/14 | Every five (5) years | Every March 1 st after a tune-up is completed | – | – | – | – | – |

A *Seasonal* boiler is one that undergoes a shutdown for a period of at least seven (7) consecutive months or 210 consecutive days within a 12-month period due to seasonal conditions, except for periodic testing. Periodic testing shall not exceed a combined total of 15 days during the 7-month shutdown.

A *Limited Use* boiler is any boiler that burns any amount of solid or liquid fuels and has a federally enforceable average annual capacity factor of no more than 10%.